



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

L. Scott Baird
Executive Director

DIVISION OF AIR QUALITY
Bryce C. Bird
Director

10237

DAQO-PR0102370015-20

July 7, 2020

Mr. Patrick Wauters
US EPA Region 8
1595 Wynkoop Street
Denver, CO 80202-1129

CERTIFIED MAIL

Dear Mr. Wauters:

Re: Operating Permit #1500101004 for PacifiCorp- Hunter Power Plant

The Division of Air Quality received an application for Operating Permit #1500101004 for PacifiCorp-Hunter Power Plant on April 17, 2020 (application #OPP0102370015). The action was classified as Title V renewal application, in accordance with R307-415-7c. The changes are as follows:

- (1) removing Emission Unit #38 and the associated condition;
- (2) updating the PAL renewal date in condition II.B.1.i.;
- (3) updating the opacity excursion to 5.33% in condition II.B.3.a.1.(b)(2)(i), based on the most recent test results;
- (4) removing the obsolete initial stack test requirements for NO_x, SO₂ and CO on all three boilers.

The Utah Division of Air Quality hereby submits the proposed Title V Operating Permit in accordance with Utah Administrative Code (UAC) R307-415-8(1)(a). There is no comment received during the public comment period. This letter initiates EPA's 45-day review period. If you have any questions regarding this permit, please contact me at (801) 536-4086 or by e-mail at jhe@utah.gov.

Sincerely,

Jennifer He
Environmental Engineer
Operating Permits Section